



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191213

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-03-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	56.41	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	55.85	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191213

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	0.96	kW
Pc Low	1.36	kW
Pec Low	23.00	W
Dpc Low	4.30	kPa
Ph Low	1.32	kW
Peh Low	23.00	W
Dph Low	3.70	kPa
Lw Low	39	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191213

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	1.14	kW
Pc Med	1.59	kW
Pec Med	29.00	W
Dpc Medium	5.70	kPa
Ph Med	1.61	kW
Peh Med	29.00	W
Dph Medium	5.20	kPa
Lw Med	42	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191213

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	1.69	kW
Pc High	2.34	kW
Pec High	51.00	W
Dpc High	10.90	kPa
Ph High	2.40	kW
Peh High	51.00	W
Dph High	10.20	kPa
Lw High	48	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191214

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-04-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	56.01	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	55.91	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191214

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	0.96	kW
Pc Low	1.36	kW
Pec Low	23.00	W
Dpc Low	4.30	kPa
Ph Low	1.32	kW
Peh Low	23.00	W
Dph Low	3.70	kPa
Lw Low	39	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191214

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	1.34	kW
Pc Med	1.87	kW
Pec Med	35.00	W
Dpc Medium	7.40	kPa
Ph Med	1.90	kW
Peh Med	35.00	W
Dph Medium	6.80	kPa
Lw Med	45	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191214

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	2.38	kW
Pc High	3.14	kW
Pec High	63.00	W
Dpc High	19.50	kPa
Ph High	3.33	kW
Peh High	63.00	W
Dph High	19.20	kPa
Lw High	52	dB(A)





# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191215

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-06-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	72.02	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	76.50	
FCCOP Class	D	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191215

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	1.90	kW
Pc Low	2.77	kW
Pec Low	35.00	W
Dpc Low	17.30	kPa
Ph Low	2.88	kW
Peh Low	35.00	W
Dph Low	16.60	kPa
Lw Low	41	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191215

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	2.20	kW
Pc Med	3.05	kW
Pec Med	48.00	W
Dpc Medium	21.30	kPa
Ph Med	3.27	kW
Peh Med	48.00	W
Dph Medium	21.30	kPa
Lw Med	47	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191215

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	2.90	kW
Pc High	4.03	kW
Pec High	67.00	W
Dpc High	33.80	kPa
Ph High	4.30	kW
Peh High	67.00	W
Dph High	33.50	kPa
Lw High	56	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191601

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-08R2-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	87.35	
Variable Speed Fan	false	
FCEER Class	C	
Mounting Base	Cassette	
FCCOP	93.11	
FCCOP Class	D	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191601

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	2.50	kW
Pc Low	3.19	kW
Pec Low	31.00	W
Dpc Low	24.30	kPa
Ph Low	3.32	kW
Peh Low	31.00	W
Dph Low	23.20	kPa
Lw Low	41	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191601

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	3.31	kW
Pc Med	4.14	kW
Pec Med	52.00	W
Dpc Medium	40.20	kPa
Ph Med	4.33	kW
Peh Med	51.00	W
Dph Medium	38.70	kPa
Lw Med	52	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191601

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	4.17	kW
Pc High	5.14	kW
Pec High	103.00	W
Dpc High	56.10	kPa
Ph High	5.43	kW
Peh High	101.00	W
Dph High	54.90	kPa
Lw High	57	dB(A)





# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191216

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-08-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	71.93	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	76.01	
FCCOP Class	D	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191216

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	1.90	kW
Pc Low	2.77	kW
Pec Low	35.00	W
Dpc Low	17.30	kPa
Ph Low	2.88	kW
Peh Low	35.00	W
Dph Low	16.60	kPa
Lw Low	41	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191216

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	2.50	kW
Pc Med	3.55	kW
Pec Med	54.00	W
Dpc Medium	27.40	kPa
Ph Med	3.76	kW
Peh Med	54.00	W
Dph Medium	26.90	kPa
Lw Med	52	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191216

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	3.20	kW
Pc High	4.48	kW
Pec High	80.00	W
Dpc High	39.70	kPa
Ph High	4.73	kW
Peh High	80.00	W
Dph High	38.80	kPa
Lw High	58	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191217

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-09-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	61.49	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	61.34	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191217

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	1.78	kW
Pc Low	2.53	kW
Pec Low	39.00	W
Dpc Low	8.30	kPa
Ph Low	2.49	kW
Peh Low	39.00	W
Dph Low	7.30	kPa
Lw Low	42	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191217

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	2.52	kW
Pc Med	3.55	kW
Pec Med	61.00	W
Dpc Medium	14.90	kPa
Ph Med	3.55	kW
Peh Med	61.00	W
Dph Medium	13.40	kPa
Lw Med	51	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191217

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	4.32	kW
Pc High	6.01	kW
Pec High	106.00	W
Dpc High	36.70	kPa
Ph High	6.09	kW
Peh High	106.00	W
Dph High	33.70	kPa
Lw High	54	dB(A)





# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191219

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-12-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	68.33	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	69.07	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191219

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	3.56	kW
Pc Low	5.02	kW
Pec Low	69.00	W
Dpc Low	18.20	kPa
Ph Low	5.02	kW
Peh Low	69.00	W
Dph Low	16.40	kPa
Lw Low	48	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191219

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	4.07	kW
Pc Med	5.71	kW
Pec Med	93.00	W
Dpc Medium	22.80	kPa
Ph Med	5.73	kW
Peh Med	93.00	W
Dph Medium	20.60	kPa
Lw Med	53	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191219

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	5.41	kW
Pc High	7.55	kW
Pec High	112.00	W
Dpc High	37.00	kPa
Ph High	7.64	kW
Peh High	112.00	W
Dph High	33.90	kPa
Lw High	59	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191220

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCG-16-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	66.48	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	67.39	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191220

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	3.56	kW
Pc Low	5.02	kW
Pec Low	69.00	W
Dpc Low	18.20	kPa
Ph Low	5.02	kW
Peh Low	69.00	W
Dph Low	16.40	kPa
Lw Low	48	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191220

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	4.77	kW
Pc Med	6.67	kW
Pec Med	110.00	W
Dpc Medium	30.00	kPa
Ph Med	6.73	kW
Peh Med	110.00	W
Dph Medium	27.40	kPa
Lw Med	55	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191220

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	6.00	kW
Pc High	8.33	kW
Pec High	152.00	W
Dpc High	44.00	kPa
Ph High	8.48	kW
Peh High	152.00	W
Dph High	40.70	kPa
Lw High	63	dB(A)





# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191222

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs convecteurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCH-09-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	61.94	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	85.08	
FCCOP Class	D	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191222

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	3.03	kW
Pc Low	4.23	kW
Pec Low	64.00	W
Dpc Low	16.50	kPa
Ph Low	4.24	kW
Peh Low	47.00	W
Dph Low	13.30	kPa
Lw Low	51	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191222

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	3.43	kW
Pc Med	4.82	kW
Pec Med	83.00	W
Dpc Medium	20.50	kPa
Ph Med	4.84	kW
Peh Med	61.00	W
Dph Medium	16.70	kPa
Lw Med	54	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191222

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	3.91	kW
Pc High	5.47	kW
Pec High	113.00	W
Dpc High	25.70	kPa
Ph High	5.43	kW
Peh High	83.00	W
Dph High	20.90	kPa
Lw High	60	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191223

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCH-10-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	69.34	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	73.51	
FCCOP Class	D	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191223

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	3.03	kW
Pc Low	4.17	kW
Pec Low	56.00	W
Dpc Low	16.50	kPa
Ph Low	4.25	kW
Peh Low	55.00	W
Dph Low	15.30	kPa
Lw Low	51	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191223

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	3.43	kW
Pc Med	4.75	kW
Pec Med	73.00	W
Dpc Medium	20.50	kPa
Ph Med	4.87	kW
Peh Med	71.00	W
Dph Medium	19.20	kPa
Lw Med	54	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201002-11191223

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	4.21	kW
Pc High	5.77	kW
Pec High	110.00	W
Dpc High	29.00	kPa
Ph High	5.98	kW
Peh High	97.00	W
Dph High	27.50	kPa
Lw High	63	dB(A)





# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191204

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCH-12-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	64.10	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	66.90	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191204

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	3.03	kW
Pc Low	4.17	kW
Pec Low	56.00	W
Dpc Low	16.50	kPa
Ph Low	4.25	kW
Peh Low	56.00	W
Dph Low	15.30	kPa
Lw Low	49	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191204

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	3.91	kW
Pc Med	5.37	kW
Pec Med	99.00	W
Dpc Medium	25.70	kPa
Ph Med	5.55	kW
Peh Med	99.00	W
Dph Medium	24.30	kPa
Lw Med	60	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191204

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	5.01	kW
Pc High	6.84	kW
Pec High	133.00	W
Dpc High	39.00	kPa
Ph High	7.21	kW
Peh High	133.00	W
Dph High	38.00	kPa
Lw High	67	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191206

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs convecteurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCH-16-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	49.41	
Variable Speed Fan	false	
FCEER Class	E	
Mounting Base	Cassette	
FCCOP	50.97	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191206

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	5.52	kW
Pc Low	7.50	kW
Pec Low	148.00	W
Dpc Low	24.10	kPa
Ph Low	7.79	kW
Peh Low	148.00	W
Dph Low	19.70	kPa
Lw Low	56	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191206

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	6.35	kW
Pc Med	8.80	kW
Pec Med	173.00	W
Dpc Medium	27.90	kPa
Ph Med	8.86	kW
Peh Med	173.00	W
Dph Medium	20.90	kPa
Lw Med	60	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191206

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	7.37	kW
Pc High	9.55	kW
Pec High	273.00	W
Dpc High	39.40	kPa
Ph High	10.24	kW
Peh High	273.00	W
Dph High	32.20	kPa
Lw High	65	dB(A)





# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191207

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs convecteurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCH-18-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	56.07	
Variable Speed Fan	false	
FCEER Class	D	
Mounting Base	Cassette	
FCCOP	59.57	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191207

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	5.52	kW
Pc Low	7.37	kW
Pec Low	128.00	W
Dpc Low	20.10	kPa
Ph Low	7.88	kW
Peh Low	128.00	W
Dph Low	20.00	kPa
Lw Low	56	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191207

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	6.35	kW
Pc Med	8.65	kW
Pec Med	150.00	W
Dpc Medium	25.10	kPa
Ph Med	9.08	kW
Peh Med	150.00	W
Dph Medium	24.30	kPa
Lw Med	58	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191207

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	7.87	kW
Pc High	10.64	kW
Pec High	260.00	W
Dpc High	36.50	kPa
Ph High	11.20	kW
Peh High	260.00	W
Dph High	35.50	kPa
Lw High	67	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191208

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Fan Coil Units / Ventilateurs (FCU)
Product type	Non-ducted/ 2 pipes/ Cooling and heating
Brand	POLAR AIR
Range	PCGH Superior Cassette
Product référence	PCH-20-V

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
FCEER	48.07	
Variable Speed Fan	false	
FCEER Class	E	
Mounting Base	Cassette	
FCCOP	53.29	
FCCOP Class	E	
Main Power Supply	230-1-50	
L M H	1 2 3	



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191208

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LOW SPEED</b>		
Ps Low	5.52	kW
Pc Low	7.37	kW
Pec Low	128.00	W
Dpc Low	20.10	kPa
Ph Low	7.88	kW
Peh Low	128.00	W
Dph Low	20.00	kPa
Lw Low	56	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191208

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>MEDIUM SPEED</b>		
Ps Medium	7.37	kW
Pc Med	9.31	kW
Pec Med	237.00	W
Dpc Medium	32.80	kPa
Ph Med	10.50	kW
Peh Med	237.00	W
Dph Medium	35.30	kPa
Lw Med	65	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072120201001-11191208

Issued on 21 July 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 11.12.003**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HIGH SPEED</b>		
Ps High	8.21	kW
Pc High	11.00	kW
Pec High	298.00	W
Dpc High	39.10	kPa
Ph High	11.70	kW
Peh High	298.00	W
Dph High	38.60	kPa
Lw High	70	dB(A)